

# Emission Test Certificate

Monday August 22<sup>nd</sup>, 2011

Supplier: Dotmar Group of Companies (25 Loyalty Road, North Rocks, NSW, 2151)


Sample Description: Nuvex Board.

Date Tested: July 2011

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2/V3 IEQ-13</b> <b>Green Star Office Design V2/V3 IEQ-14</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>Nuvex Board</b>
Total Volatile Organic Compound emission rate <0.5 mg/m <sup>2</sup> /hr (7 Days)	Total Volatile Organic Compound emission rate <0.003 mg/m <sup>2</sup> /hr (7 Days)
Formaldehyde emission rate <0.12 mg/m <sup>3</sup> hr	Formaldehyde emission rate <0.004 mg/m <sup>2</sup> /hr (24 hours)



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

CV110708b